

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1170221

Product: Heating panel

Type: NG 200 AL, NG 200 dl. AL, NG 300 AL, NG 400 AL,
NG 500 AL, NG 600 AL, NG 700 AL

Rating: 230V, 50Hz, IP20, 200W, 230W, 300W, 400W, 500W, 600W, 700W

Ordering firm: SAKUTUS CZ a.s.
Dražice 256, 391 31 Dražice, Czech Republic

Manufacturer: SAKUTUS CZ a.s.
Dražice 256, 391 31 Dražice, Czech Republic

Factories: SAKUTUS CZ a.s.
Dražice 256, 391 31 Dražice, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 700757-01/01 of: 30.03.2017

A sample of the product was found to be in conformity with:
EN 60335-1:02+A1:04+A11:04+A2:06+A12:06+A13:08+A14:10+A15:11
EN 60335-2-30:09+A11:12

Other data:

Certificate was issued on the basis of fulfillment of requirements of the "EZÚ certificate" certification scheme and on the basis of agreement No. 700757 between the client and the Electrotechnical Testing Institute.

Compliance of the product with mentioned standards and regulations ensures compliance of the product with essential requirements of Government Order No. 118/2016 Sb. (2014/35/EU) as amended and the certificate may be used as a supporting document for the EU Declaration of Conformity under Act No. 90/2016 Coll., on Conformity Assessment of Products When Made Available on the Market, as amended.

The validity of the certificate is limited to: 30.04.2020

04.04.2017

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



700757-01